



**LEWIS-CLARK STATE COLLEGE
REQUEST FOR INFORMAL BIDS
ADDENDUM #1**

Issue Date: 8/28/2024

Project: LC State Student Union Building/Center for Student Leadership – Steam Line Repairs

Project #: 240041

Owner/Agency:

Lewis-Clark State College (LC State)

Physical Plant

538 11th Ave

Lewiston, ID 83501

(208) 792-2247

Owner Contact: Redgy Erb / rgerb@lcsc.edu

Note:

Only items contained herein are changes to the bid documents. All other conditions and requirements of the bid documents are still in effect.

Pre-Bid Walkthrough:

See attached pre-bid walk-through sign-in sheet from 8/27/2024.

Questions from the Pre-Bid Walk-through, 8/27/2024:

1. The receiver pump has an 8-week lead time, can the contract time be extended to allow for this? Yes – since the steam system will still run with the existing receiver pump, the contract time can be extended to account for this anticipated material shipping time.

Exhibit A – Requirements/Specifications:

Add note #13 to read: Lokring fittings are acceptable in lieu of welded connections, for pipe and fittings up to 4" diameter.

END OF ADDENDUM #1

LC 240041 - LC STATE STUDENT UNION BUILDING
STEAM LINE REPAIRS

NAME	FIRM	PHONE #	EMAIL
Kenny Oakes	RM	208-750-0494	Kenny@rmmechanical.net
Brian Graham	LC.S.C	208-228-8928	BaGraham@lc.sc.edu
Jerry Schwartz	QC	208 507 0199	Jerry@qualitycontractors.com